



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Oct 04, 2021

Inspection Result: PASSED

Permit Number: P-20-131

Issuance Date: Mar 03, 2020

Property Address: 55950 HANNAHS WAY, ROUTT, CO 80428;

Contractor: ACTION MECHANICAL INC. P.O. BOX 698 CLARK, CO 80428 (970) 819-1174
ACTION MECHANICAL INC. P.O. BOX 698 CLARK, CO 80428 (970) 819-1174

To construct: Work Description: complete plumbing system

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All plumbing for this permit has been completed Plumbing final complete

Corrections:

Sincerely,

Don Marchbanks
Inspector
dmarchbanks@co.routt.co.us
(970) 870-5371