



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Oct 07, 2021

Inspection Result: PASSED

Permit Number: B-20-1244

Issuance Date: Feb 18, 2021

Property Address: 25525 COUNTY ROAD 56, ROUTT, CO 80487;

Contractor:

To construct: Work Description: Build new 1950 square foot single family home

Total Project Cost:

\$591,500

Owners agreement for building permit attached.

On this day we have inspected your construction for **Drywall Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: 5/8" type X drywall installed and fastened correctly on garage ceiling and separation walls. Approved to tape and finish.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347