



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Oct 07, 2021

**Inspection Result:** PASSED

**Permit Number:** B-20-1244

**Issuance Date:** Feb 18, 2021

**Property Address:** 25525 COUNTY ROAD 56, ROUTT, CO 80487;

**Contractor:**

**To construct:** Work Description: Build new 1950 square foot single family home

Total Project Cost:

\$591,500

Owners agreement for building permit attached.

On this day we have inspected your construction for **Framing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Strap added for missing hold down on stud packs between garage doors. Approved.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us  
(970) 870-5347