



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Oct 27, 2021

**Inspection Result:** PASSED

**Permit Number:** P-21-137

**Issuance Date:** Feb 10, 2021

**Property Address:** 198 E LINCOLN AVE, HAYDEN, CO 81639;

**Contractor:** IQ PLUMBING & HEATING 895 RANNEY ST CRAIG, CO 81625 (970) 629-5125

**To construct:** Work Description: I will be doing waste, vent and water piping  
UNIT C

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** All plumbing for this permit has been completed plumbing final complete

**Corrections:**

Sincerely,

Don Marchbanks  
Inspector  
dmarchbanks@co.routt.co.us  
(970) 870-5371