



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Nov 02, 2021

Inspection Result:

PARTIAL PASS

Permit Number: TB-21-922

Issuance Date: Aug 25, 2021

Property Address: 26355 HIDDEN MESA DR, ROUTT, CO 80467;

Contractor: SPITELLIE CONSTRUCTION P.O. BOX 881971 STEAMBOAT SPGS, CO 80488 (970) 846-2327

To construct: Work Description: To add a two story great room
. net cost is \$150,000
Total valuation \$200,000

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Foundation drain installed and properly bedded in gravel with filter fabric over top. Will inspect daylight at later inspection.

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us
(970) 870-5331