



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Nov 03, 2021

**Inspection Result:** NOT READY

**Permit Number:** B-20-809

**Issuance Date:** Oct 13, 2020

**Property Address:** 42375 RIVER DRUM TRL, ROUTT, CO 80487;

**Contractor:** Altitude Custom Builders P O Box 883013, 970-238-0630 Steamboat Springs, CO 80488 (970) 238-0630

**To construct:** Work Description: New construction of a Single family dwelling with attached garage.

Total Valuation \$2,402,219.

On this day we have inspected your construction for **Framing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:**

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us  
(970) 870-5347