



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Nov 04, 2021

Inspection Result: NOT READY

Permit Number: PRPL210543

Issuance Date: Nov 03, 2021

Property Address: 58000 COWBOY WAY, UNIT:B, ROUTT, CO 80428;

Contractor: MOUNTAIN HIGH MECHANICAL 6080 W 91ST CRT #2-104 WESTMINSTER, CO 80021
(970) 846-5622

To construct: Floor drains for walk in coolers.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Cancelled

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us
(970) 870-5331