



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Nov 05, 2021

**Inspection Result:**

**PARTIAL PASS**

**Permit Number:** M-20-518

**Issuance Date:** Sep 11, 2020

**Property Address:** no match:27875-B US HIGHWAY 40; 27875 US HIGHWAY 40, UNIT:B, ROUTT, CO 80487;

**Contractor:**

**To construct:** Work Description: shop/garage  
hydronic heat, propane boiler heat source

On this day we have inspected your construction for **Approval for Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Gas line stub through building has been installed correctly, pressure test good at 15 psi for 15 minutes. See corrections for green tag.

**Corrections:**

- 1 Need to install condensate treatment and drain to DWV system and cut foam back from exhaust pipe.

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us  
(970) 870-5347