

Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued:	Nov 05, 2021	Inspection Result:	PASSED
Permit Number:	PRPL210543		
Issuance Date:	Nov 03, 2021		
Property Address:	58000 COWBOY WAY, UNIT:B, ROUTT, CO 80428;		
Contractor:	MOUNTAIN HIGH MECHA	NICAL 6080 W 91ST CRT #2	2-104 WESTMINSTER, CO 80021
	(970) 846-5622		
To construct:	Floor drains for walk in co	olers.	

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: DWV lines for floor drains have been installed and bedded correctly. Pressure test good at 5 psi for 15 minutes. Approved to backfill.

Corrections:

Sincerely,

Silas Ebbert Inspector sebbert@co.routt.co.us (970) 870-5347