



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Nov 05, 2021

Inspection Result:

PARTIAL PASS

Permit Number: PRMH210544

Issuance Date: Nov 03, 2021

Property Address: 58000 COWBOY WAY, UNIT:B, ROUTT, CO 80428;

Contractor: MOUNTAIN HIGH MECHANICAL 6080 W 91ST CRT #2-104 WESTMINSTER, CO 80021
(970) 846-5622

To construct: Extending main gas line to exterior of new addition.

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: New gas line from north side of building under slab into crawlspace has been installed and bedded correctly. Pressure test good at 15 psi for 15 minutes.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347