



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Nov 08, 2021

**Inspection Result:** PASSED

**Permit Number:** PRGS210554

**Issuance Date:** Nov 05, 2021

**Property Address:** 25545 COUNTY ROAD 56, ROUTT, CO 80487;

**Contractor:** SCHRADER PROPANE LLC P.O. BOX 775450 STEAMBOAT SPGS, CO 80477 (970) 879-1432

**To construct:** EXTERIOR, UNDERGROUND GAS LINE INSTALLATION. NO TANK SET YET.

On this day we have inspected your construction for **Gas Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** New gas line has been installed and bedded correctly at correct depth. Pressure test good at 26 psi for 15 minutes. Approved to backfill.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us  
(970) 870-5347