



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Nov 09, 2021

**Inspection Result:** PASSED

**Permit Number:** PRGS210555

**Issuance Date:** Nov 05, 2021

**Property Address:** 27225 COUNTY ROAD 14, ROUTT, CO 80467;

**Contractor:** SCHRADER PROPANE LLC P.O. BOX 775450 STEAMBOAT SPGS, CO 80477 (970) 879-1432

**To construct:** TANK SET & EXTERIOR, UNDERGROUND GAS LINE INSTALLATION

On this day we have inspected your construction for **Gas Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** New propane tank and gas line has been installed and bedded at correct depth. Pressure test good at 20 psi for 15 minutes. Approved to backfill.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us  
(970) 870-5347