



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Nov 12, 2021

Inspection Result: PASSED

Permit Number: PRGS210579

Issuance Date: Nov 10, 2021

Property Address: 42375 RIVER DRUM TRL, ROUTT, CO 80487;

Contractor: SCHRADER PROPANE LLC P.O. BOX 775450 STEAMBOAT SPGS, CO 80477 (970) 879-1432

To construct: EXTERIOR, UNDERGROUND GAS LINE INSTALLATION & TANK SET

On this day we have inspected your construction for **Gas Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: New propane tank and line have been installed and bedded correctly. Pressure test good at 25 psi for 15 minutes. Approved to backfill.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347