



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Nov 12, 2021

**Inspection Result:** FAILED

**Permit Number:** PRMH210382

**Issuance Date:** Oct 07, 2021

**Property Address:** 27225 COUNTY ROAD 14, ROUTT, CO 80467;

**Contractor:** HILLSIDE PLUMBING & HEATING P.O. BOX 772647 STEAMBOAT SPGS, CO 80477  
(970) 879-7016

**To construct:** Radiant heat

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Heat tubing installed and fastened correctly for garage slab but no pressure test and too much snow on slab. Fix and reinspect.

**Corrections:**

- 1 Need to pass pressure test and clear snow from garage slab

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us  
(970) 870-5347