



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Nov 15, 2021

Inspection Result:

PARTIAL PASS

Permit Number: PRMH210382

Issuance Date: Oct 07, 2021

Property Address: 27225 COUNTY ROAD 14, ROUTT, CO 80467;

Contractor: HILLSIDE PLUMBING & HEATING P.O. BOX 772647 STEAMBOAT SPGS, CO 80477
(970) 879-7016

To construct: Radiant heat

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Hydronic tubing installed over 2 inch spray foam and properly fastened to wire mesh. Tubing test good at 100psi. Approved

Corrections:

- 1 Need to pass pressure test and clear snow from garage slab

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us
(970) 870-5331