



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Nov 17, 2021

Inspection Result: PASSED

Permit Number: PRPL210607

Issuance Date: Nov 16, 2021

Property Address: 753 DOUGHERTY RD, VACANT, ROUTT, CO 80487;

Contractor: ALPENGLOW PLUMBING & HEATING P.O. BOX 883159 STEAMBOAT SPGS,, CO 80488
(970) 871-1974

To construct: Adding gas line and heater to storage building

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: New steel gas line from meter location to unit heater has been installed and supported correctly. Pressure test good at 20 psi for 15 minutes. Approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347