



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Dec 01, 2021

Inspection Result: PASSED

Permit Number: M-20-518

Issuance Date: Sep 11, 2020

Property Address: no match:27875-B US HIGHWAY 40; 27875 US HIGHWAY 40, UNIT:B, ROUTT, CO 80487;

Contractor:

To construct: Work Description: shop/garage
hydronic heat, propane boiler heat source

On this day we have inspected your construction for **Approval for Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Boiler now ready to operate. Green tag issued.

Corrections:

- 1 Need to install condensate treatment and drain to DWV system and cut foam back from exhaust pipe.

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347