



Permit No:  
PREL210748

# ELECTRICAL

Steamboat Springs, CO

Job Address	30857 COUNTY ROAD 53, ROUTT, CO 81639	<b>ISSUED</b>	
<b>Owner</b> JMS BEAR CREEK RANCH LLC 130 CASUARINA CONCOURSE CORAL GABLES, FL 33143			
<b>Applicant</b> BEHRMAN ELECTRIC LLC 2038 WOODLAND AVE CRAIG , CO 81625 (970) 756-6801			
<b>Contractor</b> BEHRMAN ELECTRIC LLC 2038 WOODLAND AVE CRAIG , CO 81625 (970) 756-6801			
<b>Legal Description of Property</b> TR IN LOT 16, S2SE4 SEC 19-5-88; TR IN NE4 LYING NE OF CO RD 53, PT OF LOT 5 SEC 30-5-88 TOTAL: 100.94 AC (SMR REC#820842)		<b>Description of Work</b> Install three new services on property. One 100 amp meter main combo with one GFI outlet and one pole light. One 200 amp meter main combo with one GFI outlet with two pole lights. For future barn and stables. One 200 amp meter main combo with one GFI outlet by old shop on west side of property.	
<b>Parcel #</b> 943301001		<b>Type of Construction</b> New	
<b>Permit #</b>	PREL210748	<b>Permit Types</b>	Electrical

## Building Components:

Quantity	Units	Description	Unit Cost	Subtotal Cost
3	QTY	Service Panel New/Alteration Residential	\$0.00	\$0.00

Note: This Permit has been issued under the conditions that the Applicant and Owner shall conform to all adopted Local, State, and Federal regulations and the Approved Record Sets drawings. Permit is subject to being revoked at any time if violation of any provisions of said laws and ordinances occur. Applicant and Owner shall be responsible to call for all required inspections set forth in the provisions, regulations, and laws, and at minimum are required to call for progress inspections a minimum of once every 180-days to avoid permit suspension or revocation. The Applicant and Owner shall be responsible to complete all work and required inspections prior to the expiration date of Permit.

Todd Carr

SIGNED:

Building Official  
Routt County Building Department