



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Dec 29, 2021

Inspection Result: PASSED

Permit Number: B-19-499

Issuance Date: Jul 01, 2019

Property Address: no match:28300-B COUNTY ROAD 14; 28300 COUNTY ROAD 14, UNIT:B, ROUTT, CO 80467;

Applicant:

Contractor:

To construct: Detached garage with unfinished man cave above.

ADDENDUM to finish man cave above Garage and delete airlock entry. 8.20.19. MMF

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Final on stairs

Rebecca Miles, 312-806-1989

Deck railing cables attached and tensioned. Stairs installed

Corrections:

- 1 New code compliant stair need to be installed to unit and need to tighten cable rails

Sincerely,

Jeff Yeiser

Inspector

jyeiser@co.routt.co.us

(970) 870-5371

