



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Jan 03, 2022

Inspection Result:

PARTIAL PASS

Permit Number: PREL210748

Issuance Date: Dec 23, 2021

Property Address: 30857 COUNTY ROAD 53, ROUTT, CO 81639;

Applicant: BEHRMAN ELECTRIC LLC

Contractor: BEHRMAN ELECTRIC LLC 2038 WOODLAND AVE CRAIG , CO 81625 (970) 756-6801

To construct: Install three new services on property. One 100 amp meter main combo with one GFI outlet and one pole light. One 200 amp meter main combo with one GFI outlet with two pole lights. For future barn and stables. One 200 amp meter main combo with one GFI outlet by old shop on west side of property.

On this day we have inspected your construction for **Electrical Perm Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: 2 of 3 services on permit approved. the first at gate approved, second service at horse barn(approx. 300yds west, visible from road) approved. third service inaccessible due to snow has not been inspected.

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us
(970) 870-5339