



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School

Corrections Notice

Permit Application #PRAB210408

Dear Applicant,

Following are the comments regarding the plan review for the below referenced application. We have noted several concerns and/or non-conforming items regarding the work to be performed. These items must be addressed through revised drawings and/or addendum submitted to the CityView Portal for us to complete our review and approval, thank you.

Property Address: 52100 COUNTY ROAD 129, ROUTT, CO 80487

Parcel No: 924042001;

Application Type: Accessory Building

Type of Construction: Not Applicable

Occupancy:

Planning Review (Reviewed By: Chris Brookshire)

Comments: Height of cupola must meet RCZR Section 2.17 No greater than 45' in height

If I can provide any further information to you, please feel free to contact me at (970) 870-5334 or by email at mmichael-ferrier@co.routt.co.us.

Sincerely,

A handwritten signature in dark ink, appearing to read 'Malea Michael-Ferrier'.

Malea Michael-Ferrier
Administrative Assistant/Plan Reviewer Assistant
Building Services