



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Jan 18, 2022

**Inspection Result:** PASSED

**Permit Number:** B-19-682

**Issuance Date:** Oct 28, 2019

**Property Address:** no match:58000-B COWBOY WAY; 58000 COWBOY WAY, UNIT:B, ROUTT, CO 80428;

**Applicant:** Jim Stegmaier

**Contractor:** GARCIA CONSTRUCTION LIMITED 1153 OAK STREET STEAMBOAT SPRINGS, CO  
80477 (970) 757-3250

**To construct:** TO ADD A WALK-IN ADDITION TO THE EXISTING KITCHEN

On this day we have inspected your construction for **Insulation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Walls have 2" spray foam with R13 batt. Attic has R49 blown insulation. R values approved, OK for drywall.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us  
(970) 870-5347