



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Jan 26, 2022

Inspection Result: PARTIAL PASS

Permit Number: B-20-797

Issuance Date: May 12, 2021

Property Address: 27315 HOME RANCH RD, ROUTT, CO 80428;

Applicant: Paul Stoll

Contractor: SNAKE RIVER CONSTRUCTION PO BOX 773504 Steamboat Springs, CO 80477 (970) 846-2301

To construct: New Green House

On this day we have inspected your construction for **Framing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Fire separation wall steel framing has been done to approved plans, approved to insulate. Exterior knee wall steel framing and rock wool insulation installed correctly. Approved to cover. Need engineers approval on change in firewall drywall material and installation.

Corrections:

- 1 Need engineer or architects approval on changes of drywall from 1/2" type X to 1/2" type C and installed horizontally instead of vertically.

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347