

**REVIEWED
FOR
CODE
COMPLIANCE**

Structural Clarification Item #1 **01/27/2022**

Date: December 8, 2021

Project: McFarlane Arena
52100 County Road 129
Routt, CO 80487


Project Number: 21-03-064

To: Ted Allen
Plans Examiner
Routt County Regional Building Department

From: Joe Kirby, P.E.

C: Cole Hansen

Re: Permit Application #PRAB210408



Reference signed and sealed construction drawings dated September 23, 2021 and calculations dated September 24, 2021. Our responses to the Building Code Review comments are as follows:

- 1) Please refer to the attached statement of special inspections.
- 2) Structural observations are not required on this project since none of the conditions of 1704.6.1 apply. Please disregard the General Structural Note D.1. on S1, including the reference to 1709.
- 3) Please refer to the attached VP Basic Erection Guide for the metal building manufacturer's plan of compliance with ACI 318-14.
- 4) Please refer to the attached reaction report (21-007748-01 Reaction Report sealed AMW) sealed September 10, 2021, from the metal building manufacturer.

Please call with any specific questions.

Attachment: **STATEMENT OF SPECIAL INSPECTIONS, VP Basic Erection Guide, 21-007748-01 Reaction Report sealed AMW**

END OF STRUCTURAL CLARIFICATION ITEM #1