



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Feb 15, 2022

Inspection Result:

PARTIAL PASS

Permit Number: B-21-692

Issuance Date: Jul 13, 2021

Property Address: 27225 COUNTY ROAD 14, ROUTT, CO 80467;

Applicant: Jack Mical Huyser

Contractor: ALBERTINI CONSTRUCTION INC. P.O. BOX 775768 STEAMBOAT SPGS, CO 80477
(897) 846-4224

To construct: SFR w/ attached garage

On this day we have inspected your construction for **Framing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Sheer wall

Mike, 846-4447

Shear walls only, meets 3"/6" nailing schedule

Corrections:

Sincerely,

Jeff Yeiser

Inspector

jyeiser@co.routt.co.us

(970) 870-5371