



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Mar 10, 2022

Inspection Result: FAILED

Permit Number: B-20-1244

Issuance Date: Feb 18, 2021

Property Address: 25525 COUNTY ROAD 56, ROUTT, CO 80487;

Applicant: Peter Kurtz

Contractor:

To construct: Work Description: Build new 1950 square foot single family home

Total Project Cost:

\$591,500

Owners agreement for building permit attached.

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: See corrections

Corrections:

- 1 Add weather stripping to attic access
Add foam to attic access panel and make sure batts stay in place
Set self closing hinges on garage man door
Set address on sign at county road

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us

(970) 870-5347