



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Mar 11, 2022

Inspection Result: PARTIAL PASS

Permit Number: PRPL220219

Issuance Date: Mar 10, 2022

Property Address: 60880 COUNTY ROAD 129, UNIT:A, ROUTT, CO 80428;

Applicant: MOUNTAIN HIGH MECHANICAL

Contractor: MOUNTAIN HIGH MECHANICAL 6080 W 91ST CRT #2-104 WESTMINSTER, CO 80021
(970) 846-5622

To construct: New plumbing in kitchen including new floor drains, floor sinks, and new plumbing for hand sinks and dishwasher.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Subslab DWV lines in kitchen have been installed to approved plan. Pressure test good at 5 psi for 15 minutes. Approved to patch concrete.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347