



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Mar 21, 2022

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRPL220219

**Issuance Date:** Mar 18, 2022

**Property Address:** 60880 COUNTY ROAD 129, UNIT:A, ROUTT, CO 80428;

**Applicant:** MOUNTAIN HIGH MECHANICAL

**Contractor:** MOUNTAIN HIGH MECHANICAL 6080 W 91ST CRT #2-104 WESTMINSTER, CO 80021  
(970) 846-5622

**To construct:** New plumbing in kitchen including new floor drains, floor sinks, and new plumbing for hand sinks and dishwasher.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Water lines in kitchen, held at 100psi, nail plates installed

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us  
(970) 870-5371