

Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

## **INSPECTION REPORT**

Report Issued:	Mar 29, 2022	Inspection Result:	PASSED
Permit Number:	PRAD220010		
Issuance Date:	Mar 03, 2022		
Property Address:	60880 COUNTY ROAD 129, UNIT:A, ROUTT, CO 80428;		
Applicant:	YAMPA VALLEY ENGINEERING		
Contractor:	GARCIA CONSTRUCT	ION LIMITED 1153 OAK STREET	STEAMBOAT SPRINGS, CO
	80477 (970) 757-325	0	
To construct:	To add a dish room to an existing building and restaurant.		

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Foundation walls have been formed to approved plans with all rebar sized and spaced correctly. Approved to pour.

**Corrections:** 

Sincerely,

Silas Ebbert Inspector sebbert@co.routt.co.us (970) 870-5347