



Feiges Dome

As-built conditions:

- Sonotubes were not used, rather soils were bored with open-hole methods (solid silt/clay with no caving) to 4" bgs
- Foundations are 24" diameter
- #5 rebar was installed
- 4,000 psi concrete was utilized for the pour