

Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Apr 12, 2022 Inspection Result: PARTIAL PASS

Permit Number: PRMH210382 Issuance Date: Oct 07, 2021

Property Address: 27225 COUNTY ROAD 14, ROUTT, CO 80467;

Applicant: HILLSIDE PLUMBING & HEATING

Contractor: HILLSIDE PLUMBING & HEATING P.O. BOX 772647 STEAMBOAT SPGS, CO 80477

(970) 879-7016

To construct: Radiant heat

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: In floor heat tubing, main floor, pressure test, no manifold. held at 100 psi.

Corrections:

1 Need to pass pressure test and clear snow from garage slab

Sincerely,

Jeff Yeiser Inspector jyeiser@co.routt.co.us (970) 870-5371