



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Apr 13, 2022

Inspection Result: PARTIAL PASS

Permit Number: B-20-797

Issuance Date: May 12, 2021

Property Address: 27315 HOME RANCH RD, ROUTT, CO 80428;

Applicant: Paul Stoll

Contractor: SNAKE RIVER CONSTRUCTION PO BOX 773504 Steamboat Springs, CO
80477 (970) 846-2301

To construct: New Green House

On this day we have inspected your construction for **Drywall Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: First layer 1/2" type C installed and fastened correctly. Approved to install second layer.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347