



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Apr 18, 2022

Inspection Result: PARTIAL PASS

Permit Number: PRMH220364

Issuance Date: Apr 13, 2022

Property Address: 27225 COUNTY ROAD 14, ROUTT, CO 80467;

Applicant: ALPINE HEATING & SHEET METAL

Contractor: ALPINE HEATING & SHEET METAL P.O. BOX 770999 STEAMBOAT
SPGS, CO 80477 (970) 879-2396

To construct: (6) Fans
(1) Dryer
(1) Woodburning Stove

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All ducts for bath fans, dryer and make up air for hood have been installed, supported and sealed correctly. Tie in for make up air in mechanical room and wood stove to be done at later date.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347