



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Apr 18, 2022

Inspection Result: PASSED

Permit Number: PRPL210381

Issuance Date: Oct 07, 2021

Property Address: 27225 COUNTY ROAD 14, ROUTT, CO 80467;

Applicant: HILLSIDE PLUMBING & HEATING

Contractor: HILLSIDE PLUMBING & HEATING P.O. BOX 772647 STEAMBOAT SPGS,
CO 80477 (970) 879-7016

To construct: Plumbing system for new home.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: DWV, water and gas lines have been installed, supported and protected correctly. Pressure tests good for 15 minutes. Approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347