



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Apr 25, 2022

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRMH220218

**Issuance Date:** Mar 10, 2022

**Property Address:** 60880 COUNTY ROAD 129, UNIT:A, ROUTT, CO 80428;

**Applicant:** MOUNTAIN HIGH MECHANICAL

**Contractor:** MOUNTAIN HIGH MECHANICAL 6080 W 91ST CRT #2-104  
WESTMINSTER, CO 80021 (970) 846-5622

**To construct:** Make up air unit for kitchen. Unit heater for storage area. New hood for pizza oven with make up air and grease duct.

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Hydronic heat tubing has been installed and fastened correctly over 2" foam board and poly vapor barrier. Pressure test good at 100 psi for 15 minutes. Approved to pour.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us  
(970) 870-5347