



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Apr 26, 2022

Inspection Result: NOT READY

Permit Number: PRAD220010

Issuance Date: Mar 03, 2022

Property Address: 60880 COUNTY ROAD 129, UNIT:A, ROUTT, CO 80428;

Applicant: YAMPA VALLEY ENGINEERING

Contractor: GARCIA CONSTRUCTION LIMITED 1153 OAK STREET STEAMBOAT
SPRINGS, CO 80477 (970) 757-3250

To construct: To add a dish room to an existing building and restaurant.

On this day we have inspected your construction for **Framing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments:

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347