



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Apr 29, 2022

Inspection Result: PARTIAL PASS

Permit Number: M-20-518

Issuance Date: Sep 11, 2020

Property Address: no match:27875-B US HIGHWAY 40; 27875 US HIGHWAY 40, UNIT:B,
ROUTT, CO 80487;

Applicant: jamie burgessJames Burgess

Contractor:

To construct: Work Description: shop/garage
hydronic heat, propane boiler heat source

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Hydronic heat tubing has been installed and fastened correctly to second floor sheathing. Pressure test good at 80 psi for 15 minutes. Approved to cover. Water lines to upstairs sink has been installed correctly. Pressure test good at 60 psi for 15 minutes. Approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347