



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: May 06, 2022

Inspection Result: PASSED

Permit Number: PRPL220219

Issuance Date: Mar 18, 2022

Property Address: 60880 COUNTY ROAD 129, UNIT:A, ROUTT, CO 80428;

Applicant: MOUNTAIN HIGH MECHANICAL

Contractor: MOUNTAIN HIGH MECHANICAL 6080 W 91ST CRT #2-104
WESTMINSTER, CO 80021 (970) 846-5622

To construct: New plumbing in kitchen including new floor drains, floor sinks, and new plumbing for hand sinks and dishwasher.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: PCV vent lines have been installed correctly, need to see nail plates in two location at later date, water lines installed and stubbed through wall. Tested live with no leaks detected. Approved to drywall in kitchen.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347