



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** May 11, 2022

**Inspection Result:** PASSED

**Permit Number:** PRAD220010

**Issuance Date:** Mar 03, 2022

**Property Address:** 60880 COUNTY ROAD 129, UNIT:A, ROUTT, CO 80428;

**Applicant:** YAMPA VALLEY ENGINEERING

**Contractor:** GARCIA CONSTRUCTION LIMITED 1153 OAK STREET STEAMBOAT  
SPRINGS, CO 80477 (970) 757-3250

**To construct:** To add a dish room to an existing building and restaurant.

On this day we have inspected your construction for **Insulation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Walls of addition have 2" spray foam and R13 batt for R27 total and ceiling has 4" spray foam and R21 batt for R49+. Approved to install drywall.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us  
(970) 870-5347