



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: May 12, 2022

Inspection Result: PARTIAL PASS

Permit Number: PRRF220479

Issuance Date: May 06, 2022

Property Address: 35040 COUNTRY GREEN RD, ROUTT, CO 80487;

Applicant: Weddle Professional Roofing

Contractor: Weddle Professional Roofing 5707 Gunnison St Chicago, IL 60630 (785) 346-4924

To construct: Removal of the current underlayment and metal roof, foloowed by the installation of the Tesla Solar Roof (TSR). TSR is a building integrated PV system that is designed to mirror the aesthetic of traditional ashphalt shingles whie allowing the homeowner to produce energy for their home.

On this day we have inspected your construction for **Roofing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Tesla roof, mid roof inspection. Tesla underlayment installed, double layer on eave projections per mfr.

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371