



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: May 18, 2022

Inspection Result: PARTIAL PASS

Permit Number: B-20-809

Issuance Date: Oct 13, 2020

Property Address: 42375 RIVER DRUM TRL, ROUTT, CO 80487;

Applicant: Nathan Reynolds

Contractor: Altitude Custom Builders P O Box 883013, 970-238-0630 Steamboat Springs, CO 80488 (970) 238-0630

To construct: New construction of a Single family dwelling with attached garage.

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: See conditions, approved for TCO for 60 days. All other final building and life safety items are complete. Partial approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347