



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** May 19, 2022

**Inspection Result:** FAILED

**Permit Number:** PREL220537

**Issuance Date:** May 17, 2022

**Property Address:** 6985 HOMESTEADER LN, ROUTT, CO 81639;

**Applicant:** CENTRAL ELECTRIC, LLC

**Contractor:** CENTRAL ELECTRIC, LLC 2659 Jacob Cir #4 STEAMBOAT SPGS,, CO  
80487 (970) 846-8379

**To construct:** New circuit for transfer switch for backup generator. Existing pedestal, adding circuit for generator.

On this day we have inspected your construction for **Electrical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Service entrance section structural integrity breached as stated in previous inspection 230.7 other conductors may not occupy the same raceway as service feeders 230.8 service entrance must be capable of being sealed

**Corrections:**

Sincerely,

Tom Cook  
Electrical Plan Reviewer/Inspector  
tcook@co.routt.co.us  
(970) 870-5339