



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** May 20, 2022

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRPL220219

**Issuance Date:** Mar 18, 2022

**Property Address:** 60880 COUNTY ROAD 129, UNIT:A, ROUTT, CO 80428;

**Applicant:** MOUNTAIN HIGH MECHANICAL

**Contractor:** MOUNTAIN HIGH MECHANICAL 6080 W 91ST CRT #2-104  
WESTMINSTER, CO 80021 (970) 846-5622

**To construct:** New plumbing in kitchen including new floor drains, floor sinks, and new plumbing for hand sinks and dishwasher.

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** All plumbing completed to scope of permit except dishwasher that was being hooked up at time of inspection. Hammer arrester to be installed is on back order, contractor is going to install expansion tank in the meantime. Partial Approved

## Corrections:

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us  
(970) 870-5331