



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: May 20, 2022

Inspection Result: PARTIAL PASS

Permit Number: PRAD220010

Issuance Date: Mar 03, 2022

Property Address: 60880 COUNTY ROAD 129, UNIT:A, ROUTT, CO 80428;

Applicant: YAMPA VALLEY ENGINEERING

Contractor: GARCIA CONSTRUCTION LIMITED 1153 OAK STREET STEAMBOAT SPRINGS, CO 80477 (970) 757-3250

To construct: To add a dish room to an existing building and restaurant.

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All work completed to scope of permit including shaft liner completion except..

- 1-Need to submit Ansel report for hood.
 - 2-Need to complete grid ceiling at Type 1 hood.
 - 3-Need to complete guardrail around make up air on back roof.
 - 4 Need to finish install of roofing on back of building.
 - 5 Need to install Stainless Steel doors between bar and kitchen.
- OK to TCO

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us
(970) 870-5331