



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Jun 06, 2022

Inspection Result: PARTIAL PASS

Permit Number: PRFO210132

Issuance Date: Feb 22, 2022

Property Address: 27315 HOME RANCH RD, ROUTT, CO 80428;

Applicant: SNAKE RIVER CONSTRUCTION

Contractor: SNAKE RIVER CONSTRUCTION PO BOX 773504 Steamboat Springs, CO
80477 (970) 846-2301

To construct: Alteration and addition to existing lodge.

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: North stem walls have been formed correctly over caisson piers and void forms. All rebar is sized and spaced correctly. Large double mat spread footer in western part of lodge has been formed correctly. Approved to pour.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347