



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Jun 16, 2022

**Inspection Result:** PASSED

**Permit Number:** B-20-797

**Issuance Date:** May 12, 2021

**Property Address:** 27315 HOME RANCH RD, ROUTT, CO 80428;

**Applicant:** Paul Stoll

**Contractor:** SNAKE RIVER CONSTRUCTION PO BOX 773504 Steamboat Springs, CO  
80477 (970) 846-2301

**To construct:** New Green House

On this day we have inspected your construction for **Drywall Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Fire wall between office space and greenhouse has been fire taped correctly. All walls and ceiling of office has 5/8" type X drywall installed and fastened correctly. Approved to finish.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us  
(970) 870-5347