



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Jul 05, 2022

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRFO210132

**Issuance Date:** Feb 22, 2022

**Property Address:** 27315 HOME RANCH RD, ROUTT, CO 80428;

**Applicant:** SNAKE RIVER CONSTRUCTION

**Contractor:** SNAKE RIVER CONSTRUCTION PO BOX 773504 Steamboat Springs, CO  
80477 (970) 846-2301

**To construct:** Alteration and addition to existing lodge.

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** 2" spray foam installed correctly under garage slab.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us  
(970) 870-5347