



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Jul 14, 2022

Inspection Result: PASSED

Permit Number: PRAB210377

Issuance Date: Mar 08, 2022

Property Address: 39620 AMETHYST DR, ROUTT, CO 80487;

Applicant: Pascal Ginesta HLCC CONSTRUCTION CO.

Contractor: HLCC CONSTRUCTION CO. 2667 COPPER RDG CIR #2 STEAMBOAT
SPGS, CO 80487 (970) 879-6831

To construct: 3 sided standard wood construction pole building, metal roof and exterior wall
covering.. Being built at Strawberry Park Elementary School used for
implement and maintenance storage.

On this day we have inspected your construction for **Footing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: 14 piers and Bigfoot bases in proper locations on Approved Plans. Rebar installed is sized and spaced correctly. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us
(970) 870-5331