



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Jul 19, 2022

Inspection Result: FAILED

Permit Number: PREL220958

Issuance Date: Jul 18, 2022

Property Address: 30535 MARSHALL RIDGE, ROUTT, CO 80487;

Applicant: A-PEKS ELECTRIC

Contractor: A-PEKS ELECTRIC 300 Blackberry Ln steamboat, CO 80487 (970) 734-5050

To construct: New electric

On this day we have inspected your construction for **Electrical Temp Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Meter socket cover missing service lateral not trenched to transformer vault

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us
(970) 870-5339