



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Jul 21, 2022

Inspection Result: PASSED

Permit Number: TB-21-934

Issuance Date: Sep 17, 2021

Property Address: 50310 MOON HILL DR, ROUTT, CO 80487;

Applicant: Nathan NicholasNathan Nicholas

Contractor: Mr. Gumpox Industries P O Box 773434 Steamboat Springs, Co 80477
(970) 819-6740

To construct: 1,797 square foot single family home with detached garage.

On this day we have inspected your construction for **Framing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: SIP installed and fastened correctly to each other, sill 2x6 and to interior timbers with timberlock screws. Main floor framing has been done to approved plans. All interior framing is good. Approved to insulate when MEP rough inspections pass.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347